



# Santa Rosa County Life Safety/Fire Prevention Department

Santa Rosa County Public Service Center  
6051 Old Bagdad Highway, Room 202  
Milton, Florida 32583

**John T. "Tim" Tolbert**  
Building Official  
**Skip Tompkins**  
Compliance Division Superintendent

Telephone  
850.981.7000  
Fax 850.623.1208

**Tambre L. Lee**  
Fire Inspector/ Plans Examiner  
**Annie Sue Rambo**  
Fire Inspector

## Underground Fire Main Application

**\*\*Attention:** If your job is located within the city limits of Milton or Midway Fire Protection District, please do not fill out this application. You will need to contact the City of Milton Fire Department or Midway Fire Department \*\*

**\*\*Please submit two sets of site plans indicating location and details of underground fire main\*\***

Date \_\_\_\_\_

L/S Permit # \_\_\_\_\_  
Bldg. Permit # \_\_\_\_\_  
**Office Use Only**

Project Name: \_\_\_\_\_

Project Physical Address: \_\_\_\_\_

### Type of Building:

New Construction

Existing Building

Remodel/Addition

Description of work to be done: \_\_\_\_\_

Type of pipe being installed: \_\_\_\_\_

**Notice to Applicant:** Prior to issuance of a permit, we must have on file a current copy of the following:

- (1) State license,
- (2) Occupational License
- (3) Liability insurance
- (4) Workman's compensation.

### Underground Fire Main Sequence of inspections:

- (1) Rough-in inspection of pipe and thrust blocks
- (2) Pressure test (**INSPECTOR MUST WITNESSED PRESSURE-UP OF PIPE AND DURATION OF TEST**)
- (3) Final test and certification inspection.

Contractor: \_\_\_\_\_

Contractor State Registration Number: \_\_\_\_\_

Contractor's Mailing Address: \_\_\_\_\_

Contractor's Phone Number: \_\_\_\_\_

Contact Person: \_\_\_\_\_

**ALL INSPECTIONS MUST BE CALLED IN AND SCHEDULED WITH THE LIFE SAFETY/ FIRE PREVENTION DEPARTMENT 24 HOURS IN ADVANCE.**

#### Florida State Statue 633.529

(3) For contracts written after June 30, 2005, the contractor who installs the underground piping from the point of service is responsible for completing the installation to the aboveground connection flange, which by definition in this chapter is no more than 1 foot above the finished floor, before completing the Contractor's Material and Test Certificate for Underground Piping document. Aboveground contractors may not complete the Contractor's Material and Test Certificate for Underground Piping document for underground piping or portions thereof which have been installed by others.

\_\_\_\_\_  
Signature of Person Applying

\_\_\_\_\_  
Printed Name of Applicant